

# Attestation

## Italian CAM

### Heavy Metals in Dry Film of Paint

On 18<sup>th</sup> October 2022, Eurofins Product Testing A/S received a sample of a paint with the product name :

## **SUPERQUARZ PLUS**

supplied by

## **Ivas Industria Vernici Spa**

The heavy metals in dry film of paint were tested according to the Italian CAM Edilizia Decree DM 23 Giugno 2022 n. 254, GURI n. 184 del 8 agosto 2022 section 2.5.13 b section. Testing and evaluation were performed according to ISO 17294m:2016 for chromium and selenium and DS 259:2003, SM 3120 ICP-OES for arsenic, cadmium, lead and mercury. (see the test report no. 392-2022-00455606\_XN\_EN).

### **Evaluation of heavy metals in dry film of paint result according to Italian CAM:**

- Single heavy metal concentrations of cadmium, lead, hexavalent chromium, mercury, arsenic and selenium is below 0.010 % by weight in dry paint on the tested sample.

14 November 2022



Pernille Krintel  
Analytical Service Manager