

Ivas Industria Vernici Spa
Via Bellaria 40
47030 San Mauro Pascoli (FC)
ITALY

Eurofins Product Testing Denmark A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD

20 June 2024

1 Sample Information

Sample name	QUARZOGUM PLUS BASE P
Batch no.	-
Stated production date	04/04/2024
Product type	Paint
Sample reception	11/04/2024

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
French VOC Regulation §		Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A)
French CMR components §	Pass	Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A)
Italian CAM Edilizia	Pass	DM 23 giugno 2022 n. 256, GURI n. 183 del 6 agosto 2022
ABG/AgBB	Fail	Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021)
Belgian Regulation	Fail	Royal decree of May 2014 (C-2014/24239)
Indoor Air Comfort	Fail	Indoor Air Comfort 9.0 of June 2023
Indoor Air Comfort GOLD	Fail	Indoor Air Comfort GOLD 9.0 of June 2023
Blue Angel (DE-UZ 12a)	Fail	DE-UZ 12a for "Low-emission and low-pollutant paints and varnishes", January 2019
EU Taxonomy	Fail	Regulation (EU) 2020/852 of the European Parliament and of the Council

Full details based on the testing and direct comparison with limit values are available in the following pages

Regarding pass/fail decision rule please see appendix

§ See section 4.4 on deviations


Frederik Foged Haugaard
Analytical Service Manager


Rasmus Verdier
Analytical Service Manager